



Confirmation

eurofins

Eurofins Product Testing A/S confirms that a sample of a cement based screed with the name

UZIN NC 157
supplied by
Uzin Utz AG

showed low VOC emissions in a test in accordance with the *“Standard Method for the Testing and Evaluation of VOC Emissions from Indoor Sources using Environmental Chambers, version 1.1 of February 2010 by the California Department of Public Health”*, as specified in indoor air emission criteria of Collaborative for High Performance Schools (CHPS), Indoor Advantage Gold TN certification, Floorscore and LEED credit 4.3 (flooring systems).

Emissions were below all limit values specified in that standard practice.

The test has been performed in July 2013, see test report no. 392-2013-00032301. The testing methodology is covered by independent ISO 17025 accreditation, issued by DANAK (# 522).

With this confirmation, use of product may qualify for fulfillment of LEED credit IEQ 4.3 (flooring systems).

29 August 2013

Thomas Neuhaus
Head of product emission test centre

Eurofins Product Testing A/S
Smedeskovvej 38
DK 8464 Galten / Denmark

Tel +45 70 22 42 76
Fax +45 70 22 42 75

www.product-testing.eurofins.com